

Study Received Date:





Bacterial Filtration Efficiency (BFE) Final Report

Test Article: Filti Mask Material Testing Facility: Nelson Laboratories, LLC 6280 S. Redwood Rd.

Salt Lake City, UT 84123 U.S.A.

Study Number: 1292279-S01 Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18

Deviation(s): None

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of Staphylococcus aureus was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at 1.7 - 3.0 x 103 colony forming units (CFU) with a mean particle size

23 Apr 2020

(MPS) of 3.0 \pm 0.3 μ m. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside **Conditioning Parameters:** $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5\%$ C for a minimum of 4 hours

BFE Test Area: ~40 cm²

BFE Flow Rate: 28.3 Liters per minute (L/min) **Negative Monitor Count:** <1 CFU

Positive Control Average: 3.3 x 10³ CFU MPS: 2.6 µm

Results

Test Article Number	Percent BFE (%)
1	99.6
2	99.5
3	99.6
4	99.3
5	99.4

The filtration efficiency percentages were calculated using the following equation:

$$\%BFE = \frac{C-T}{C} \times 100$$

$$C = Positive control average$$

$$T = Plate count total recover$$

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request







If you have any questions, please